

Record No.

Outside Catering Equipment / Installation Gas Safety

Inspection Date:

22/7/15



0121 603 2524

Gas Safe Engineers Card No:	3591425	Installation type:	Gazebo	Operators Name:	LUCY BATES
Name:	Kevin Mawby	Marquee, Gazebo, Stall		Company:	TOASTIE
Company:	Caterfix	Size (ft)/(m)	5x5 metres	Address:	7 ACADEMIA AVE
Address:	Peterborough		+		BROXBORNE
Post Code:	PE1 5XL		Trailer	Post Code:	HERTS EN10 6FW
Phone:	01733 561535			Phone:	07968 977939

Appliances	Make	Model	CE marked Yes / No	Fixing Satisfactory Yes / No	Ventilation Satisfactory Yes / No	Location Satisfactory Yes / No	Isolation Valve Installed Yes / No	Controls Operation Satisfactory Yes / No	Burner Pressure / Co	POC Removal Satisfactory Yes / No
Griddle (Outside)	M2 Data Plate	AWB6P	NO	NO	yes	yes	NO	yes	37bar	yes
Boiler (Trailer)	Perry	AWB6P	yes	yes	yes	yes	NO	yes	37bar	yes

LPG Cylinder Storage	Satisfactory Yes/No or N/A	Installation	Satisfactory Yes/No	Extract	Satisfactory Yes/No	Defects Identified:	Warning / Advice note No.
Cage	N/A	EIV	NA	Interlock	NO	Main burner on boiler running low and has yellow tips.	Trailer may need cleaning.
Ventilation	yes	Pipe Sizing	NA	Smoke Test	NO		
Location	yes	Hose condition	yes			Remedial Action:	
Warning Label	NO	Pipework Condition	yes	Fire Precautions	Satisfactory Yes/No		
Changing Instruction	NO	Joints	yes	Extinguisher	yes	Engineers Signature: ✓	Name (Printed):
Securing Method	yes	Gas Tightness	yes	Blanket	yes	Date: 22/7/15	Next Inspection Date:
Tamper Resistance	NO	Operating Pressure	77bar			Operator signature:	Date:
Regulator	yes	Lock Up Pressure	40bar				